

Office of Sub Divisional Officer.
P.H.Sub Division, Ara.

Letter no:- 722,

Date:- 28/04/2022,

Certificate regarding safe drinking water and sanitary condition

It is certified that an inspection team headed by Sri.Suraj Kumar, Assistant Engineer, from Public Health Engineering Department, Ara inspected the Sanskriti Public School Kayamnagar Bhojpur on 27/04/2022 and founded that Sanskriti Public School Kayamnagar Bhojpur has safe drinking water facilities for students and members of staff of institution and is maintaining the hygienic condition in school building & the campus.

Signature with Seal:-.....

Name:-.....

Designation:-.....

Suraj Kumar
28/4/22
Sub-divisional Officer
P.H. Sub-division
Ara

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

Division Name: P.H.Division, Ara

Date Of Sampling: 25/04/22
Date Of Testing: 27/04/22

District Name: Bhojpur (Ara)
Sample Collected By: J.E. Koliwar

Sl. No.	Block	Panchyat	Village	Habitation	Location of Source	Parameters																	Total Coll	Remarks
						pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO ₃	SO ₄	F	As					
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22			
1	Koliwar	KayamNagar	KayamNagar	KayamNagar	Sanskriti Public School (Handpump)	7.55	4.8	590	460	160.7	41.68	15.55	23	176.40	0.35	NT	NT	0.12	0.002	-Ve	Safe			
2	Koliwar	KayamNagar	KayamNagar	KayamNagar	Sanskriti Public School (R.O.Water)	8.11	0.3	507	380	152.9	40.08	12.63	19	172.48	0.14	NT	NT	0.08	BDL	-Ve	Safe			
Permissible Limit* in absence of alternative source						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	0.01	-	-			
*NT= Not Tested, BDL=Below Detection Limit						NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	-	-			

Qaej
27-04-22
Ead Daej

Sankar Kumar
27/04/22
अला स्तरीय जल जाल प्रयोगशाला
लोक स्वास्थ्य प्रमण्डल आरा